

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

GRANT CO Health Department Installation Permit No. SS1295035

Name of Owner RICHARD C & MARGARET L WILSON

Address 18192 MARYLAND HIGHWAY, SWANTON, MD. 21561

Property Address NORTH FORK RETREAT SUBDIVISION LOT 9 SECTION A

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served MOBILE HOME No. Water Closets _____

Lot Size 1 Acre sq. ft. Area suitable for sewage disposal installation 10,000 sq. ft.

Source of Water Supply PUBLIC No. Lavatories _____

No. Bedrooms 3 No. Showers or Tubs _____ No. Baths _____

No. Garbage Grinders _____ No. Automatic Washers _____

SEPTIC TANK

PRE-CAST
Material CONCRETE Length _____ x Width _____ x Depth _____ = _____ cubic feet

Liquid Depth _____ ft. Liquid Capacity 1000 gal.

Distance to: Dwelling 14' Water Supply N/A Nearest Property Line 10'

SOIL ABSORPTION SYSTEM

Type Drain Line Material PLASTIC Trench Width 36 Inches
Trench Depth 36 Inches Total Absorption area in Trench Bottom 720 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media LIMESTONE CHIPS

No. of Drain Lines 3 Depth Filter Media Under Drain Line 6-8 Inches

Length of Each Line 100, 100, 30, _____ ft. Depth Filter Media Over Drain Line 2 in.

Distance of Disposal Field to: (a) Dwelling 29'

(b) Water Supply N/A (c) Nearest Property Line EST. 40' (Side)

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

19 APRIL 95
Date

Max M. Fisher, R.S.
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

